

**ANNEXURE – V (a)**

**HT NET METER Solar Rooftop PV system Synchronization Report/Test Report  
PART A**

**Applicant Details**

1	Net Meter Registration Number	
2	Registration Date	
3	Name of the applicant	
4	Service Number	
5	Category	
6	Load	
7	Distribution/Section	
8	Address	
9	Mobile No	

CEIG Approval Ref No: \_\_\_\_\_

**Solar Rooftop PV system Connection details:**

Sl No.	Date	Inter Connection Point (LT Bus/HT Bus)	Existing Solar Capacity if any	Now Commissioned Capacity	Total Capacity
1.					

**PV Modules Details:**

Sl No.	Make	Serial Number	Type of Module	No. of modules	Capacity of each Module	Total capacity
1.						
2.						

**Details of protective system available :**  
(Commissioning shall be done only on availability of the protective equipment)

**Old Meter details:**

Meter Make	Serial No.	Class	Capacity	MF	Final Readings on Dt:_____
					_____ kWh, _____ kVAh

**New Meter details:**

Meter Make	Serial No.	Class	Capacity	MF	Initial Readings on Dt:_____	
					Import	Export
					_____ kWh, _____ kVAh	_____ kWh, _____ kVAh

**PART B**

**(Project Completion Report for Grid-Connected Rooftop)**

**Installation Details**

Category of the customer:		Sub Category of the Customer :	
Name of the plant owner:			
Mobile :		Email :	
Address of Installation :		PIN Code of Installation Address :	
State of Installation Address :		District of Installation Address:	
Project Model (CAPEX/RESCO):			
Date of Commissioning of the plant:		Total Cost of Installation (Rs.):	
Whether installation is (Rooftop only/ Rooftop plus ground)			
Plant Capacity (kWp) (Rooftop only)		Plant Capacity(kWp) (Ground only)	
Total plant capacity(kWp)			

**Installed Project Latitude -Longitude Info**

Latitude:	
Longitude:	

**Upload Documents**

- 1) Photo of Installed plant  
(File Format accepts only: JPG, JPEG, PNG and Maximum Size: 2Mb)
- 2) Electricity DisCom Bill  
(File Format accepts only: Pdf and Maximum Size: 1Mb)

**C E R T I F I C A T E**

It is certified that there is no return voltage from the inverter to the meter when incoming grid supply is switched off.

It is further certified that the protective equipment is installed and functioning as prescribed.

The above Solar Rooftop PV system was synchronized as per DISCOM guidelines and the performance of the above plant is satisfactory. The date of synchronization of the plant is

\_\_\_\_\_.

**Vendor Signature  
(with stamp)**

**Eligible Consumer DE/M&P \_\_\_\_\_ DE/Op \_\_\_\_\_**

**ANNEXURE-V(b)**

**LT NET METER Solar Rooftop PV system Synchronization Report /Test Report**

<b>A</b>	<b><u>Applicant Details</u></b>	
1	Net Meter Registration Number	
2	Registration Date	
3	Name of the applicant	
4	Service Number	
5	Category	
6	Load	
7	Distribution/Section	
8	Pole number	
9	Address	
10	Mobile No	
<b>B</b>	<b><u>Old Meter Details</u></b>	
1	Meter make	
2	Serial number	
3	Capacity	
4	MF	
5	Final reading	
	i) kWh	
	ii) kVAh	
6	Date of replacement	
<b>C</b>	<b><u>New Net Meter Details</u></b>	
1	Meter make	
2	Serial number	
3	Capacity	
4	Meter constant	
5	Initial reading (Tri vector parameters)	
	i) Import (kWh/kVAh)	_____ kWh, _____ kVAh
	ii) Export (kWh/kVAh)	_____ kWh, _____ kVAh
<b>D</b>	<b>Details of protective system available</b> (Commissioning shall be done only on availability of the protective equipment)	

**PART B**

**(Project Completion Report for Grid-Connected Rooftop)**

**Installation Details**

Category of the customer:		Sub Category of the Customer :	
Name of the plant owner:			
Mobile :		Email :	
Address of Installation :		PIN Code of Installation Address :	
State of Installation Address :		District of Installation Address:	
Project Model (CAPEX/RESCO):			
Date of Commissioning of the plant:		Total Cost of Installation (Rs.):	
Whether installation is (Rooftop only/ Rooftop plus ground)			
Plant Capacity (kWp) (Rooftop only)		Plant Capacity(kWp) (Ground only)	
Total plant capacity(kWp)			

**Installed Project Latitude –Longitude Info**

Latitude:	
Longitude:	

**Upload Documents**

- 1) Photo of Installed plant  
(File Format accepts only: JPG, JPEG, PNG and Maximum Size: 2Mb)
- 2) Electricity DisCom Bill  
(File Format accepts only: Pdf and Maximum Size: 1Mb)

**C E R T I F I C A T E**

It is certified that there is no return voltage from the inverter to the meter when incoming grid supply is switched off.

It is further certified that the protective equipment is installed and functioning as prescribed.

The above Solar Rooftop PV system was synchronized as per DISCOM guidelines and the performance of the above plant is satisfactory. The date of synchronization of the plant is \_\_\_\_\_.

**Vendor Signature  
(with stamp)**

**Eligible Consumer ADE/M&P \_\_\_\_\_ ADE/Op \_\_\_\_\_**