

Corrigendum II
to
Tender No. TSREDCO /SE / PM-KUSUM /2023-24, Dt:26-02-2024
Tender ID: 504246

S.No	As Per Tender Document/ Amendment	Amendment
1	SECTION – IV TECHNICAL SPECIFICATIONS 2. Inverter and Remote Monitoring System New added sub clause 2.13 for Invertor sections	<p>I. For 800 KW Ground Mounted SPV Power plant at Argonda, Kamareddy</p> <p>The bidder can choose the invertor capacity equivalent to 800 kW for the proposed capacity with single invertor capacity of 800 KW or multiple invertors whose total capacity should be equivalent to 800 kW. The bidder has to take the approval of the SLD of both AC and DC side before proceeding further with construction from TSREDCO.</p> <p>II. For 200 KW Ground Mounted SPV Power plant at Yellandu, Bhadradi kothagudem</p> <p>The bidder can choose the invertor capacity equivalent to 200 kW for the proposed capacity with single invertor capacity of 200 KW or multiple invertors whose total capacity should be equivalent to 200 kW. The bidder has to take the approval of the SLD of both AC and DC side before proceeding further with construction from TSREDCO.</p>

SD/-

VC&MD